

# Mount Allison University Potable Water Sampling Program

## - Charlotte House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	Lead Concentration ug/L	
		1st Reading	2nd Reading
CHAR 1	Main Floor Bottle Filler	<0.1	
CHAR 2	Main Floor Kitchen Sink Right Sink	0.6	
CHAR 3	Main Floor Kitchen Sink Left Sink	4.6	
CHAR 4	Main Floor Bathroom Right Sink	0.7	
CHAR 5	Main Floor Bathroom Left Sink	0.6	
CHAR 6	Second Floor Bathroom Right Sink	0.4	
CHAR 7	Second Floor Bathroom Middle Sink	0.5	
CHAR 8	Second Floor Bathroom Left Sink	0.5	

**Value** - Exceeds Health Canada Guidelines for Drinking Water Quality of 5 ug/L

# Mount Allison University Potable Water Sampling Program - Hammond House

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	1st Reading	2nd Reading
Hammond 1	Kitchen	<0.1	
Hammond 2	Bar sink - betw kitchen and dining	<0.1	
Hammond 3	Main floor - washroom	<0.1	
Hammond 4	Master suite washroom		







# Mount Allison University Potable Water Sampling Program

## - Hunton House

Guideline for Canadian Drinking Water Quality: 5ug/L

Location ID	Location Description	1st Reading	2nd Reading
Hunton 1	3rd floor - bathroom 1 (314 E)	3.8	
Hunton 2	3rd floor - bathroom 2 (314 D)	4.7	
Hunton 3	3rd floor - bathroom 3 (314 C)	2.1	
Hunton 4	3rd floor - bathroom 4 (314 B)	0.5	
Hunton 5	3rd floor - bathroom 5 (314 A)	4.6	
Hunton 6	3rd floor - bathroom 6 (311 A)	1.1	
Hunton 7	3rd floor - bathroom 7 (311 B)	2.5	
Hunton 8	3rd floor - bathroom 8 (311 C)	3.0	
Hunton 9	3rd floor - bathroom 9 (311 D)	7.4	<0.1
Hunton 10	3rd floor - bathroom 10 (311 E)	2.8	
Hunton 11	2nd floor - bathroom 1 (214 E)	0.9	
Hunton 12	2nd floor - bathroom 2 (214 D)	2.7	
Hunton 13	2nd floor - bathroom 3 (214 C)	9.5	0.2
Hunton 14	2nd floor - bathroom 4 (214 B)	5.2	0.9
Hunton 15	2nd floor - bathroom 5 (214 A)	3.1	
Hunton 16	2nd floor - bathroom 6 (211 A)	4.4	
Hunton 17	2nd floor - bathroom 7 (211 B)	1.6	
Hunton 18	2nd floor - bathroom 8 (211 C)	3.9	
Hunton 19	2nd floor - bathroom 9 (211 D)	5.8	0.2
Hunton 20	2nd floor - bathroom 10 (211 E)	3.3	
Hunton 21	1st floor - bathroom 1 (114 E)	0.4	
Hunton 22	1st floor - bathroom 2 (114 D)	1.8	
Hunton 23	1st floor - bathroom 3 (114 C)	0.8	
Hunton 24	1st floor - bathroom 4 (114 B)	2.6	
Hunton 25	1st floor - bathroom 5 (114 A)	3.4	
Hunton 26	1st floor - bathroom 6 (111 A)	3.8	
Hunton 27	1st floor - bathroom 7 (111 B)	3.8	
Hunton 28	1st floor - bathroom 8 (111 C)	0.6	
Hunton 29	1st floor - bathroom 9 (111 D)	0.4	
Hunton 30	1st floor - bathroom 10 (111 E)	2.9	
Hunton 31	1st floor - Hydration Station	<0.1	
Hunton 32	Basement Kitchen	1.0	0.1



**Mount Allison University Potable Water Sampling Program  
- Jennings Hall**

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location





# Mount Allison University Potable Water Sampling Program - Marjorie Young Bell Music Conservatory

Guideline for Canadian Drinking Water Quality: 5 ug/L

Location ID	Location Description	1st Reading	2nd Reading
Music 1	Ground male sink 1	1.5	
Music 2	Ground male sink 2	5.2	1.2
Music 3	Ground female sink 1		

